# **OWNER'S MANUAL**

# COMMERCIAL DEHUMIDIFIER

TCA-1080D-240V1P-CF











HIGH AIR **FLOW** 



CAPACITY

IMPORTANT: After unpacking (or accidental tip-over) allow dehumidifier to stand upright for 1 hour before starting

# **Directory**

| IMPORTANT SAFETY INSTRUCTIONS | <b>1</b>  |
|-------------------------------|-----------|
| STRUCTURE OF PRODUCT          | 1-2       |
| INSTALLATION SKETCH           | <b>3</b>  |
| CONTROL PANEL                 | 3-4       |
| PROTECTION FUNCTION           | 5         |
| CAUTION IN USE                | ······6   |
| COMMON FAULTS REMOVING        | <b></b> 7 |
| MAINTENANCE OF MACHINE        | 8         |
| TECHNICAL PARAMETERS          | 9         |
| PERFORMANCE                   | 10        |
| WHAT IN THE BOX               | 11        |


### IMPORTANT SAFETY INSTRUCTIONS


Please read all the instructions carefully before using the machine

- Confirm power supply is 240V/60Hz
- Do not power on/off the machine by connecting/cutting the power supply
- Do not roll or damage the power cord when install or remove the machine
- Do not put fingers or any other rod like object into the machine
- Remove power cord before cleaning or maintain the machine
- Make sure to connect the ground lead
- Don't do any change of machine unless guiding by our technicians

Attention: The machine has loss and dislocation phase protector, when the connected three phases outer power supply is not correct as the machine setting, the protector will be disconnected, all the indicator on control panel will be regularly display, but the machine will not run. Please correct the power supply phase connection, and restart the machine at this condition. This operation requires professional electric technicians.


### STRUCTURE OF PRODUCT






\*Make sure suitable space to install the machine
If the unit have to be installed close to wall, then try to keep machine air intake area and air outlet area more than 24in distance from the wall.

## **INSTALLATION SKETCH**



Attention: Install the machine stably with screw suspender on the ceiling, and make sure installation in flat.

### **CONTROL PANEL**



#### Operation

- 1. The screen turn on and display ambient humidity and temperature when power on the dehumidifie
- 2. Press "Power on/off" button to start the dehumidifie
  - Press "Setting" once to set target humidity.
  - Press "Setting" twice to set timed on hours.
  - Press "Setting" thrice, to set timed off hours.
  - Press "Setting" quartic back to running display.
- 3. "Humi +"Press the key to set the humidity value up with 1%RH scale in running mode.

  Press the key to set the hour up with 1 hour scale in timed on/off setting mode.
- 4. "Humi -"Press the key to set the humidity value down with 1%RH scale in running mode.

  Press the key to set the hour down with 1 hour scale in timed on/off setting mode.
- 5. "Humidity display" Current ambient humidity display when in standby / dehumidifying mode.

  Blinking when at humidity setting mode.
- 6. "RUN" Light on when dehumidifying mode and Blinking when in the 3 minutes delay protection mode.
- 7. "Defrosting indicator light" Blinking when the machine is automatic defrosting
- 8. "Timed on/off and clock display" Blinking when in timed on/off or clock setting mode
- 9. "Dehumidifying" Light on when dehumidifying mode and Blinking when in the 3 minutes delay protection mode.

#### **Functions**

- 1. The machine go into standby mode when connect to power supply (plug), LCD screen light and display current ambient humidity and temperature.
- 2. Press the "Power on/off" key to start the machine
- 3. Humidity setting: press"+" or "-" key to adjust humidity you want, the dehumidifier will start workin when the set humidity is 3% less than the current humidity, the dehumidifier will stop working whe the set humidity 3% more than the current humidity. Humidity setting range RH10%~95%.
- 4. Time set: press the "SET" key into timed on setting mode, "on" light blinking, press "+" or "-" to set hours up or down. Press the "SET" key again into timed off setting mode, "off" light blinking, then press "+" or "-" to set hours up or down. Press the "SET" key exit timed on/off setting mode. Please return hours to zero when you don't need the timed on/off function after power off, the machine have memory function when you power on.
- 5. After setting the timed on/off, if the machine is shutdown, it will run all the timed on/off setting; if the machine is running, it will run timed off setting only. Set the timed on/off time to 00 hours when you don't need the function.

### PROTECTION FUNCTION

#### 1. Automatic defrost protection function

The dehumidifier will defrost automatically when it frost on a certain level on the evaporator, compressor shutdown. The dehumidifier will start automatically when defrosting finished.

#### 2. Compressor delay start protection function

If you want to start the machine in 3 minutes after shutdown dehumidifier, the compressor will start after 3 minutes for delay protection.

#### 3. Error code

| CODE | DESCRIPTION                               | SOLUTIONS   |
|------|---|---|
| E1   | Coil temperature<br>sensor error          | check the data wire or replace new sensor           |
| E2   | Room temperature<br>humidity sensor error | check the data wire or replace new sensor           |
| E6   | Compressor pressure protection            | fill enough r frigerant and check the leakage point |

### **CAUTION IN USE**

- Do not tilt the machine more than 45 ° in moving or installation to avoid damage to the compressor.
- · Please try to seal environment better to increase the effect of dehumidifier
- · Do not place the machine in the area which may come into contact with water or chemical.
- · Do not use any relay, extension line or adapter to connect the power of machine.
- Do not place the machine next to the stove, heater and other equipment will dissipate heat, and area with direct sunlight or wind and rain.
- · Do place the plug stably and clean the dust on power line.
- Do not damage or modify the power line, do not repair by yourself and disassemble or modify the machine.
- · Do place the drainage tube smoothly for continuously drain.
- · Please shutdown the machine and cut power when in malfunction.

### **COMMON FAULTS REMOVING**

| FAILURE PHENOMENON CAUSE ANALYSIS                            |                                     | PROCESSING METHOD   |  |
|--|-------------------------------------|---|--|
|  | Power cut                           | Restore the power   |  |
|  | Power is not normal                 | Restore power   |  |
| The machine is not running                                   | Power plug is not<br>plugged in     | Put plug into the receptacle                                |  |
|  | Fuse blowout                        | Replace the fuse  |  |
|  | Filter Clogged                      | Clean the fil er  |  |
| Poor dehumidifi ation function                               | Air inlet and outlet blocked        | Remove obstructions to make good ventilation                |  |
|  | Windows and doors is not closed     | Close doors and windows and vents                           |  |
|  | Refrigerant leakage                 | Contact for maintenance                                     |  |
|  | Doors and windows<br>are not closed | Close doors and windows and vents                           |  |
| Cannot reach suitable humidity level after long time running | Vapour source existed in the room   | Close vapour source   |  |
| lever after forig time ranking                               | Room too large                      | Provide right room size to buy correct machine and quanties |  |
| Noise abnormally   | The machine placed not stably       | Place the machine stably                                    |  |
|  | Filter Clogged                      | Clean the fil er  |  |

<sup>1.</sup> When the malfunction can not be removed and recognized, please contact the supplier for maintenance service, do not attempt to disassemble the machine to repair without guide.

<sup>2.</sup> When the malfunction can not be removed and recognized, please contact the supplier for maintenance service, do not attempt to disassemble the machine to repair without guide.

<sup>3.</sup> Discharge hot air from outlet is a normal phenomenon.

### MAINTENANCE OF MACHINE

Shutdown the machine and cut power before maintenance.

#### General maintenance

Wipe the body with soft cloth in daily use. Use a wet hard cloth to wipe dirty body, or use a soft cloth moistened with a little diluted neutral detergent.

#### Regular maintenance

Filter Cleaning: it will affect the dehumidifying effect or cause malfunction if accumulate dust on filter, it needs to be cleaned regularly, clean it at least once a month. Use dust catcher to remove dust or put filter into clean water to wash, then place filter back after cleaning.

#### P.S.


The filter cannot be put in sunlight directly or roasted to avoid distortion. The filter must be place before power up machine.

#### Long time of non-use

Cut the power or unplug power line to put it in dry and shady place. Do not put down the machine to avoid damage and malfunction.

Customer Support TriCleanAir 972-656-9032 info@tricleanair.com

### **USING DRY CONTACTS (REMOTE CONTROL)**



### Tips:

Recommend 20g or Larger Wire
R- Supplies 24VAC
DHUM- When Powered Will Activate Dehumidification Mode
C- Common


## **TECHNICAL PARAMETERS**

| Model no.             | TCA-1080D-240V1P-CF  |  |
|-----------------------|----------------------|--|
| Input Voltage         | 240V-60Hz            |  |
| Rated input power     | 6.5 Kw               |  |
| Rated input current   | 27 A                 |  |
| Air flow              | 3296 CFM             |  |
| Applying area         | 2500 sqft            |  |
| Refrigerant           | R32/2.65lbs*2        |  |
| Nominal dehumidifying | 1080 PPD @ 80F/60%RH |  |
| Working temperature   | 40 - 105 F           |  |
| Gross weight          | 540 lbs              |  |
| Net Weight            | 432 lbs              |  |
| Overall dimension     | 58*47*28 in          |  |

It will be not noticed additionally if any change of above parameters, please contact with supplier.

## **Performance**

| Temp | 60% RH | 80% RH |
|------|--------|--------|
| 50F  | 300    | 320    |
| 60F  | 720    | 750    |
| 70F  | 910    | 925    |
| 80F  | 1080   | 1118   |
| 90F  | 1190   | 1210   |



# What in the box

| PICTURE                                | DESCRIPTION               | QUANTITY |
|--|---------------------------|----------|
| USETS MANAGE.  And the find markets    | User's Manual             | 1        |
|  | Dehumidifier              | 1        |
| ************************************** | Control Panel             | 1        |
|  | Surface Wire Box          | 1        |
|  | 3/4" Water Pipe Connector | 1        |
|  | Filter screen             | 1        |
|  |                           |          |
|  |                           |          |
|  |                           |          |
|  |                           |          |